



## **CALIFORNIA STATE FIRE MARSHAL LISTED, COMBINATION FIRE AND BURGLAR FIRE ALARM CONTROL PANELS**

**DATE:** January 6, 2017

**INFORMATION BULLETIN:** E-16-008

**APPROVED BY:** J. McDowell

### **Policy:**

#### **2016 California Fire Code, Section 907.1.5**

A fire alarm system shall not be used for any purpose other than fire warning or mass notification and where permitted by NFPA 72.

Combination fire and burglar systems are not approved for use within the City of Riverside based on the following:

Battery back up to be dedicated to fire equipment.

Unlicensed personnel working on fire alarm control panel.

Burglar devices (quantity, type, calculations) are hard to regulate.